



Public Works Department ♦ 2660 Civic Center Dr ♦ Roseville, MN 55113
 Phone: 651-792-7004 ♦ PublicWorks@cityofroseville.com

FIRE HYDRANT INSPECTION FORM

Hydrant ID #:		Location on Property:				
Inspection Date:		Inspector Name:				
Property Owner:						
Property Address:						
Hydrant Type (check one):	59	Clow	Muller	Pacer	Other:	
Year Built:						

TESTING, INSPECTION & MAINTENANCE	PASS	FAIL	IF FAILED, EXPLAIN
1) Hydrant can be easily opened/closed and nut is in good condition?			
2) Hydrant opened fully and flowed until clear?			
3) Hydrant barrel is free from cracks, leaks, physical damage and corrosion?			
4) Does hydrant barrel drain?			
5) Is hydrant accessible for fire department use? (minimum 3' clearance around hydrant)			
6) Does hydrant have marker?			
7) All caps not damaged, rotating smoothly, cap gaskets present and outlet connection threads lubricated and in good condition?			

FAILED items shall be corrected IMMEDIATELY by a city approved contractor.
MNFC Section 508.5.2 Fire hydrant systems shall be maintained in an operative condition at all times, and shall be repaired where defective.
PLEASE CALL 651-792-7004 WHEN FAILED ITEMS ARE FIXED FOR REINSPECTION.

Upon completion of inspection was hydrant tagged OUT OF SERVICE?	<input type="checkbox"/> YES	<input type="checkbox"/> NO
--	------------------------------	-----------------------------